



DEPARTMENT OF PERMITTING, ENVIRONMENT, AND REGULATORY
AFFAIRS (PERA)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99
www.miamidade.gov/pera

GenFlex Roofing Systems

A Division of Firestone Building Products Company, LLC

250 West 96th Street

Indianapolis, IN 46260

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County PERA - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. PERA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: TPO Single Ply Roof Systems over Steel Deck.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 06-1010.07 and consists of pages 1 through 24.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 11-0330.14
Expiration Date: 07/17/13
Approval Date: 06/14/12
Page 1 of 24

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Single Ply Roofing
Material: TPO
Deck Type: Steel
Maximum Design Pressure: -105.0 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product Name</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
GenFlex TPO	45", 75", 96", 120" or 148" wide x 100' long x 45 or 60 mils thick	TAS 131 ASTM D 6878	Polyester reinforced Thermo Plastic Olefin single ply membrane.
GenFlex TPO Plus	48" or 96" wide by 100' long x 70 or 80 mils thick	TAS 131 ASTM D 6878	Polyester reinforced Thermo Plastic Olefin single ply membrane.
GenFlex TPO Peel & Stick HW	18.75", 37.5", 75", 120" wide x 100' long x 45 or 60 mils thick	TAS 131 ASTM D 6878	Polyester reinforced Thermo Plastic Olefin single ply membrane with a self-adhered backing and heat weld laps.
GenFlex TPO Peel & Stick SA	18.75", 37.5", 75" wide x 100' long x 45 or 60 mils thick	TAS 131 ASTM D 6878	Fiberglass scrim reinforced Thermo Plastic Olefin single ply membrane with a self-adhered backing, and self-adhering laps.
GenFlex TPO Bonding Adhesive	5 gallon pails	Proprietary	Solvent based, contact adhesives for bonding of roof membrane to substrate.

APPROVED INSULATIONS:

TABLE 2

<u>Product</u>	<u>Product Description</u>	<u>Manufacturer</u> (With current NOA)
ACFoam II	Isocyanurate insulation	Atlas Roofing Corp.
ACFoam Composite	Isocyanurate insulation with perlite facer	Atlas roofing Corp.
ENRGY 3, ENRGY 3 Plus	Isocyanurate insulation with wood fiberboard facer	John Manville
Multi-Max FA-3	Isocyanurate insulation	R-Max, Inc.
Thermarroof Composite-3	Isocyanurate insulation with perlite facer	R-Max, Inc.
Structodek High Density Fiberboard Roof Insulation	Wood fiberboard insulation	Blue Ridge Fiberboard, Inc.
DensDeck, DensDeck Prime	Silicon treated gypsum	G-P Products
ISO 95+ GL	Isocyanurate insulation	Firestone Building Products
GenFlex ISO 3	Polyisocyanurate foam core insulation	GenFlex Roofing Systems
High Density Fiber Board	Wood fiberboard insulation	Generic



APPROVED FASTENERS:

TABLE 3

<u>Fastener No.</u>	<u>Product</u>	<u>Product Description</u>	<u>Manufacturer (With current NOA)</u>
1.	GenFlex Metal Anchor Bar	Batten Bar	GenFlex Roofing Systems
2.	GenFast Polymer Batten Strip	Batten Bar	GenFlex Roofing Systems
3.	GenFast #15 (WH) Fastener	Insulation and membrane fasteners	GenFlex Roofing Systems
4.	GenFlex #15 XHD Screw	Insulation and membrane fasteners	GenFlex Roofing Systems
5.	GenFlex 2-3/8" Barbed Seam Plate	Seam Plates	GenFlex Roofing Systems
6.	GenFast 3" Max Seam Plate	Seam Plates	GenFlex Roofing Systems
7.	GenFast #16 Max Fastener	Insulation and membrane fasteners	GenFlex Roofing Systems
8.	GenFast (WH) 2-3/8" Seam Plate	Seam Plates	GenFlex Roofing Systems
9.	GenFast #12 Fastener	Insulation and membrane fasteners	GenFlex Roofing Systems
10.	GenFlex #16 SXHD Fastener	Insulation and membrane fasteners	GenFlex Roofing Systems
11.	GenFast #14 Fastener	Insulation and membrane fasteners	GenFlex Roofing Systems
12.	GenFast 3" Round Insulation Plate	Stress Plates	GenFlex Roofing Systems
13.	Dekfast 12	Insulation and membrane fasteners	SFS Intec, Inc.
14.	Dekfast 14	Insulation and membrane fasteners	SFS Intec, Inc.
15.	ITW Buildex #15 Roofgrip Screw	Insulation and membrane fasteners	ITW Buildex Corp.
16.	OMG Heavy Duty	Insulation and membrane fasteners	OMG, Inc.
17.	OMG XHD	Insulation and membrane fasteners	OMG, Inc.
18.	OMG XHD Plate	Seam Plates	OMG, Inc.
19.	OMG 3" Round Metal Plates and Fasteners	Seam Plates and Fasteners	OMG, Inc.
20.	TruFast HD (#14) Fastener	Insulation and membrane fasteners	Tru-Fast Corp.
21.	TruFast SS HD (#14) Fastener	Insulation and membrane fasteners	Tru-Fast Corp.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Factory Mutual Research	3009797	FM 4470	02/04/02
	3007119	FM 4470	01/02/02
	3005794	FM 4470	12/13/01
	3002357	FM 4470	05/16/00
	3005415	FM 4470	02/08/00
	3002775	FM 4470	09/16/99
	3000919	FM 4470	04/07/99
	3003690	FM 4470	03/29/99
	3B9A2.AM	FM 4470	01/25/99
	4B1A9.AM	FM 4470	09/09/98
	1D9A7.AM	FM 4470	07/31/98
	1D9A0.AM	FM 4470	07/30/98
	1D0A3.AM	FM 4470	09/24/97
	1B0A9.AM	FM 4470	05/09/97
	3012149	FM 4470	08/28/02
	3015927	FM 4470	01/26/04
	3019052	FM 4470	01/28/05
	3023988	FM 4470	09/29/05
	3025484	FM 4470	05/31/06
	3026594	FM 4470	06/01/06
	3025659	FM 4470	06/02/06
	3027476	FM 4470	08/11/06
	3027946	FM 4470	10/18/06
Exterior Research & Design, LLC.	8054.02.02-1	Physical Properties	02/22/02
		TAS 131	
IRT-ARCON, Inc.	01-012	Wind Uplift, TAS 114, (FMRC 4470)	04/26/01
		ASTM D6878	
Momentum Technologies, Inc.	EX30M3B		06/17/04
Underwriters Laboratories, Inc.	01NK14490	Fire Classification	06/01/01
	96NK22037	TAS 114, (UL 790)	03/10/97
	01NK25823	Wind Uplift, TAS 114, (UL 1897)	07/02/01
	02NK47751	Fire Classification	10/10/03
	04NK04226	Fire Classification	11/12/04
		ASTM D6878	
Trinity ERD	F8300.11.08-2-R1		11/24/08



APPROVED ASSEMBLIES:

Membrane Type:	Single Ply, TPO
Deck Type 2I:	Steel, Insulated
Deck Description:	18 – 22ga. steel
System Type B:	Base Layer of insulation mechanically attached, optional top insulation layer fully adhered with approved asphalt or adhesive.

All General and System Limitations apply.

<u>Insulation for Base Layer</u>	<u>Fastener Density/ft²</u>	<u>Fastener Type</u>
ACFoam II, H-Shield, ISO 95+GL, ENRGY 3		
Minimum 1.4" thick	1:2	OMG 3" Round Metal Plates and Fasteners

Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Insulation for Top Layer (Optional)</u>	<u>Fastener Density/ft²</u>	<u>Fastener Type</u>
ACFoam II, H-Shield, ISO 95+GL, ENRGY 3		
Minimum 1.4" thick	N/A	N/A
DensDeck, DensDeck Prime		
Minimum 1/4" thick	N/A	N/A

Note: Optional top layer of insulation shall be adhered to the deck in full coating of OlyBond Adhesive Fastener at a rate of 1 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate

Membrane: GenFlex TPO or GenFlex TPO Plus adhered to insulation using GenFlex TPO Bonding Adhesive applied at 30 ft²/gal (0.7 m²/L) to both the substrate and the bottom side of the roof cover for a combined rate of 60 ft²/gal (1.5 m²/L)
Or
GenFlex TPO Peel & Stick HW, self-adhered to insulation with 3" wide laps sealed with a minimum 1.5" wide heat weld or primed with GenFlex Clear Primer and sealed with GenFlex 3" White TPO Seam Tape
Or
GenFlex TPO Peel & Stick SA, self adhered to insulation with minimum 3" wide laps. Laps are primed with GenFlex Clear Primer and hand rolled.

Maximum Design Pressures: -45 psf; (See General Limitation #9)

Membrane Type: Single Ply, TPO

Deck Type 2I: Steel, Insulated

Deck Description: 18-22 ga. Steel

System Type C(1): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

<u>Insulation Base Layer (Optional)</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
------------------------------------------------	-----------------------------------------------	-----------------------------

One of the following covered with the boards listed Top Layer.

GenFlex ISO 3 (flat or tapered), ACFoam II (flat or tapered)

Minimum: 1.3" thick	N/A	N/A
---------------------	-----	-----

ACFoam Composite (flat or tapered), Multi-Max FA-3, Thermarook Composite-3

Minimum: 1.5" thick	N/A	N/A
---------------------	-----	-----

Approved High Density Fiberboard, Structodek High Density Fiberboard Roof Insulation

Minimum: ½" thick	N/A	N/A
-------------------	-----	-----

<u>Insulation Top Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
------------------------------------	-----------------------------------------------	-----------------------------

GenFlex ISO 3 or ACFoam II

Minimum: 1.5" thick	1:2	See approved fasteners in table 3
---------------------	-----	-----------------------------------

Minimum: 2.0" thick	1:4	See approved fasteners in table 3
---------------------	-----	-----------------------------------

DensDeck, DensDeck Prime

Minimum: ¼" thick	1:1.8	See approved fasteners in table 3
-------------------	-------	-----------------------------------

Membrane: GenFlex TPO or GenFlex TPO Plus adhered to insulation using GenFlex TPO Bonding Adhesive applied at 30 ft²/gal (0.7 m²/L) to both the substrate and the bottom side of the roof cover for a combined rate of 60 ft²/gal (1.5 m²/L)

Maximum Design

Pressure: -45 psf; (See General Limitation #9)

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. Steel
System Type C(2): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

<u>Insulation Base Layer (Optional)</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
GenFlex ISO 3 Minimum: 1.5" thick	N/A	N/A
<u>Insulation Top Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
GenFlex ISO 3 Minimum: 1.5" thick	1:2	GenFast #12 or #14 Fasteners with plates

Membrane: GenFlex TPO Peel & Stick HW, self-adhered to insulation with 3" wide laps sealed with a minimum 1.5" wide heat weld or primed with GenFlex Clear Primer and sealed with GenFlex 3" White TPO Seam Tape
 Or
 GenFlex TPO Peel & Stick SA, self adhered to insulation with minimum 3" wide laps. Laps are primed with GenFlex Clear Primer and hand rolled.

Maximum Design Pressure: -45.0 psf; (See General Limitation #9)

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. Steel
System Type C(3): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

<u>Insulation Base Layer (Optional)</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
Any Approved insulation listed in Table 2		
Minimum: 0.25" thick	N/A	N/A

<u>Insulation Top Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
Approved High Density Fiberboard		
Minimum: 1.0" thick	1:2	GenFast #12 or #14 Fasteners with plates

Membrane: GenFlex TPO Peel & Stick HW, self-adhered to insulation with 3" wide laps sealed with a minimum 1.5" wide heat weld or primed with GenFlex Clear Primer and sealed with GenFlex 3" White TPO Seam Tape
 Or
 GenFlex TPO Peel & Stick SA, self adhered to insulation with minimum 3" wide laps. Laps are primed with GenFlex Clear Primer and hand rolled.

Maximum Design Pressure: -45 psf; (See General Limitation #9)

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. Steel
System Type C(4): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

One of the following insulations.

<u>Insulation Base Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
Any approved insulation in Table 2		
Minimum: 0.25" thick	N/A	N/A
<u>Insulation Top Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
GenFlex ISO 3, ACFoam II		
Minimum: 1.5" thick	1:1.78	GenFast #14 Fasteners, GenFast 3" Round Insulation Plates
GenFlex ISO 3, ACFoam II		
Minimum: 2.0" thick	1:1.78	GenFast #14 Fasteners, GenFast 3" Round Insulation Plates

Note: All layers shall be simultaneously fastened; see top or base layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: GenFlex TPO or GenFlex TPO Plus adhered to insulation using GenFlex TPO Bonding Adhesive applied to both the substrate and the bottom side of the roof cover for a combined rate of 65 ft² /gal (1.6 m²/L)

Maximum Design Pressure: -52.5 psf; {for 1.5" insulation} (See General Limitation #7)
-60.0 psf; {for 2" insulation} (See General Limitation #7)

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. Steel
System Type C(5): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

<u>Insulation Base Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
Any approved insulation listed in Table 2		
Minimum: 0.25" thick	N/A	N/A
<u>Insulation Top Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
ACFoam III		
Minimum: 2" thick	1:1.79	GenFast #14 Fasteners with plates

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: GenFlex TPO Peel & Stick HW, self-adhered to insulation with 3" wide laps sealed with a minimum 1.5" wide heat weld or primed with GenFlex Clear Primer and sealed with GenFlex 3" White TPO Seam Tape
 Or
 GenFlex TPO Peel & Stick SA self-adhered to insulation with minimum 3" wide laps. Laps are primed with GenFlex Clear Primer and hand rolled.

Maximum Design Pressure: -67.5 psf; (See General Limitation #7)

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. Steel
System Type D(1): Membrane attached over preliminary fastened insulation.

All General and System Limitations apply.

Deck: 18-22 ga., 1.5 in (38mm) deep, ASTM A653 or A1008 Grade 33 or Grade 80 steel deck (see fastening options for specific steel grade)

Fire Barrier: (Optional) Minimum ⁵/₈" gypsum board or ¼" DensDeck, loose laid

<u>Insulation Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
--------------------------------	-----------------------------------------------	-----------------------------

GenFlex ISO 3 (flat or tapered), ACFoam II (flat or tapered)

Minimum: 1.3" thick	N/A	N/A
---------------------	-----	-----

ACFoam Composite (flat or tapered), Multi-Max FA-3, Thermarook Composite-3

Minimum: 1.5" thick	N/A	N/A
---------------------	-----	-----

Approved High Density Fiberboard, Structodek High Density Fiberboard Roof Insulation

Minimum: ½" thick	N/A	N/A
-------------------	-----	-----

Note: All insulation shall be preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimensions greater than 4 ft., and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: GenFlex TPO or GenFlex TPO Plus attached to deck as follows:

Fastening #1: GenFlex 2-3/8" Barbed Seam Plates and GenFlex #15 XHD Screws or OMG XHD Plates and OMG XHD Screws spaced at 12 in. (305mm) o.c. within the minimum 4.5 in. (114mm) wide laps, which are spaced at 70 in (1778mm) o.c. and sealed with a minimum 1.5 in (38mm) heat weld. Minimum grade 80 steel deck.

Fastening #2: GenFast #15 (WH) Fasteners and GenFast (WH) 2-3/8" Seam Plates or GenFlex #15 XHD Screws and GenFlex 2-3/8" Barbed Seam Plates or OMG XHD Screws and OMG XHD Plates spaced at a maximum 12in (352 mm) o.c. within the minimum 6in (150 mm) wide laps, which are spaced at a maximum 90 in (2285 mm) o.c. and sealed with a minimum 1.75 in (45 mm) heat weld placed on the outside edge of the lap. Minimum grade 80 steel deck.

Fastening #3: GenFast #15 (WH) Fasteners and GenFast (WH) 2-3/8" Seam Plates or GenFlex #15 XHD Screws and GenFlex 2-3/8" Barbed Seam Plates or OMG XHD Screws and OMG XHD Plates spaced at a maximum 6 in (150mm) o.c. within the minimum 6 in (150 mm) wide laps, which are spaced at a maximum 114 in (2895 mm) o.c. and sealed with a minimum 1.75in (45mm) heat weld placed on the outside edge of the lap. Minimum grade 33 steel deck.

Fastening #4: GenFast #15 (WH) Fasteners and GenFast (WH) 2-3/8" Seam Plates or OMG XHD Screws and OMG XHD Plates spaced at 12 in. (305 mm) o.c. within the minimum 5 in (127 mm) wide laps, which are spaced at 70 in (1778 mm) o.c. and sealed with a minimum 2 in (51 mm) wide heat weld placed on the outside edge of the lap. Minimum grade 80 steel deck.

Fastening #5:

GenFast #15 (WH) Fasteners and GenFast Polymer Batten Strip. Screws are spaced at maximum 12 in (305 mm) o.c. within the minimum 4.5 in (114 mm) wide laps, which are spaced at maximum 140.5 in (3,568 mm) o.c. and sealed with a minimum 1.5 in (40 mm) wide heat weld placed on the outside edge of the batten strip and a minimum 1.0 in (25 mm) wide heat weld placed on the inside edge of the batten strip. Minimum grade 33 steel deck.

**Maximum Design
Pressure:**

-45 psf (See General Limitation #7)

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. steel
System Type D(2): Membrane attached over preliminary fastened insulation

All General and System Limitations apply.

Deck: 18-22 ga., 1.5 in (38mm) deep, ASTM A653 or A1008 Grade 80 steel deck secured to 0.25 in (6mm) structural supports spaced a maximum 6ft o.c. with Buildex Teks 4 or Teks 5 fasteners spaced max. 6 in o.c.

Fire Barrier: (Optional) Minimum 5/8" gypsum board or 1/4" DensDeck, loose laid

<u>Insulation Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
--------------------------------	-----------------------------------------------	-----------------------------

One or more layers of any of the following insulation under those listed Top layer:

GenFlex ISO 3 (flat or tapered), ACFoam II (flat or tapered)

Minimum: 1.3" thick	N/A	N/A
---------------------	-----	-----

ACFoam Composite (flat or tapered), Multi-Max FA-3, Thermarook Composite-3

Minimum: 1.5" thick	N/A	N/A
---------------------	-----	-----

Note: All insulation shall be preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimensions greater than 4 ft., and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: GenFlex TPO or GenFlex TPO Plus attached to deck as follows:

Fastening #1: GenFlex #15 XHD Screws spaced max. 6 in. (152 mm) o.c. through GenFlex Metal Anchor Bars. The bars and fasteners are placed within min. 4.5 in. (114 mm) wide laps, which are spaced at max 70.25 in. (1784 mm) o.c. and sealed with a min. 0.75 in. (19 mm) wide heat weld on the inside of the lap and a min 1 in. (25 mm) wide heat weld on the outside of the lap.

Maximum Design Pressure: -75 psf.

Fastening #2: GenFlex #15 XHD Screws spaced max 12 in. (305 mm) o.c. through GenFlex Metal Anchor Bars. The bars and fasteners are placed within min. 4.5 in (114 mm) wide laps, which are spaced at max 70.25 in. (1784 mm) o.c. and sealed with a min. 0.75 in. (19 mm) wide heat weld on the inside of the lap and a min. 1 in. (25 mm) wide heat weld on the outside of the lap.

Maximum Design Pressure: -52.5 psf.

Fastening #3: GenFlex #15 XHD Screws spaced max 6 in. (152 mm) o.c. through GenFlex Metal Anchor Bars. The bars and fasteners are placed within min. 4.5 in. (114 mm) wide laps, which are spaced at max. 142.5 in. (3620 mm) o.c. and sealed with a min. 1 in. (25 mm) wide heat weld on the inside of the lap and a min. 1 in. (25 mm) wide heat weld on the outside of the lap.

Maximum Design Pressure: -52.5 psf.

Fastening #4: GenFast #15 (WH) Fasteners and GenFast Polymer Batten Strip. Screws are spaced at maximum 6 in. (152 mm) o.c. within minimum 5 in. (127 mm) wide laps, which are spaced at maximum 144 in (3,658 mm) o.c. and sealed with a minimum 1.0 in. wide heat weld on inside of lap and a minimum 1.5 in. (40 mm) wide heat weld placed on the outside edge of the batten strip. **Maximum Design Pressure: -52.5 psf.**

Maximum Design Pressure:

See Membrane Fastening Options above. (See General Limitation #7)



Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. Steel
System Type D(3): Membrane attached over preliminary fastened insulation.

All General and System Limitations apply.

Deck: 18-22 ga., 1.5 in (38mm) deep, ASTM A653 or A1008 Grade 80 steel deck secured to 0.25 in (6mm) structural supports spaced a maximum 5.5 ft o.c. with Buildex Tek 4 or Tek 5 fasteners spaced max. 6 in o.c.

Fire Barrier: (Optional) Minimum $\frac{5}{8}$ " gypsum board or $\frac{1}{4}$ " DensDeck, loose laid

<u>Insulation Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
--------------------------------	-----------------------------------------------	-----------------------------

One or more layers of any of the following insulation under those listed Top layer:

GenFlex ISO 3 (flat or tapered), ACFoam II (flat or tapered)

Minimum: 1.3" thick	N/A	N/A
---------------------	-----	-----

ACFoam Composite (flat or tapered), Multi-Max FA-3, Thermarroof Composite-3

Minimum: 1.5" thick	N/A	N/A
---------------------	-----	-----

Note: All insulation shall be preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimensions greater than 4 ft., and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: GenFlex TPO or GenFlex TPO Plus attached to deck as follows:

Fastening: GenFlex #15 XHD Screws spaced max. 6 in. (152 mm) o.c. through GenFlex Metal Anchor Bars. The bars and fasteners are placed within min. 4.5 in. (114 mm) wide laps, which are spaced at max 142.5 in. (3620 mm) o.c. and sealed with a min. 1 in. (25 mm) wide heat weld on the inside of the lap and a min 1 in. (25 mm) wide heat weld on the outside of the lap.

Maximum Design

Pressure: -60 psf (See General Limitation #7)

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. steel
System Type D(4): Membrane attached over preliminary fastened insulation

All General and System Limitations apply.

Deck: 18-22 ga., 1.5 in (38mm) deep, ASTM A653 or A1008 Grade 80 steel deck secured to 0.25 in (6mm) structural supports spaced a maximum 6 ft o.c. with Buildex Tek 4 or Tek 5 fasteners spaced max. 6 in o.c.

Fire Barrier: (Optional) Minimum $\frac{5}{8}$ " gypsum board or $\frac{1}{4}$ " DensDeck, loose laid

One or more layers of any of the following insulation:

<u>Insulation Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
Any approved polyisocyanurate listed in Table 2		
Minimum: 1.0" thick	N/A	N/A

Note: All insulation shall be preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimensions greater than 4 ft., and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: GenFlex TPO or GenFlex TPO Plus attached to deck as follows:

Fastening #1: GenFast (WH) 2-3/8" Seam Plates and ITW Buildex #15 Roofgrip Screws spaced maximum 6 in. o.c. within minimum 6 in. wide lap. Laps are spaced at maximum 144 in. o.c. and sealed with minimum 1.75 in. wide heat weld on the outside edge of the lap.

Maximum Design Pressure: -45.0 psf (See General Limitation #7)

Fastening #2: GenFast 3" Max Seam Plates and GenFast #16 Max Fasteners spaced maximum 12 in. o.c. within minimum 6 in. wide laps. Laps are spaced maximum 114 in. o.c. and sealed with minimum 1.75 in. wide heat weld on the outside edge of the lap.

Maximum Design Pressure: -45.0 psf (See General Limitation #7)

Maximum Design Pressure:

See Membrane Fastening Options Above

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. steel
System Type D(5): Membrane attached over preliminary fastened insulation

All General and System Limitations apply.

Fire Barrier: (Optional) Minimum $\frac{5}{8}$ " gypsum board or $\frac{1}{4}$ " DensDeck, loose laid
 One or more layers of any of the following insulation:

<u>Insulation Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
Any approve polyisocyanurate listed in Table 2		
Minimum: 1.0" thick	N/A	N/A

Note: All insulation shall be preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimensions greater than 4 ft., and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: GenFlex TPO or GenFlex TPO Plus attached to deck as follows:

Fastening #1: GenFast 3" Max Seam Plate and GenFast #16 Max Fasteners spaced maximum 6 in. o.c. within minimum 6 in. wide laps. Laps are spaced maximum 144 in. o.c. and sealed with a minimum 1.75 in. wide heat weld located on the outside edge of the lap.

Maximum Design Pressure: -45.0 psf (See General Limitation #7)

Fastening #2: GenFlex #16 SXHD Fasteners spaced 6 in. o.c. within minimum 6 in. wide lap. Laps are spaced at maximum 144 in. o.c. and sealed with minimum 1.75 in. wide heat weld on the outside edge of the lap.

Maximum Design Pressure: -45.0 psf (See General Limitation #7)

Fastening #3: GenFast 3" Max Seam Plate and GenFast #16 Max Fasteners spaced maximum 12 in. o.c. within minimum 6 in. wide laps. Laps are spaced maximum 90 in. o.c. and sealed with a minimum 1.75 in. wide heat weld located on the outside edge of the lap.

Maximum Design Pressure: -45.0 psf (See General Limitation #7)

Maximum Design Pressure: See Membrane Fastening Options Above

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. steel
System Type D(6): Membrane attached over preliminary fastened insulation

All General and System Limitations apply.

Deck: 18-22 ga., 1.5 in (38mm) deep, ASTM A653 or A1008 Grade 80 steel deck secured to 0.25 in (6mm) structural supports spaced a maximum 6 ft o.c. with Buildex Tek 4 or Tek 5 fasteners spaced max. 6 in o.c.

Fire Barrier: (Optional) Minimum $\frac{5}{8}$ " gypsum board or $\frac{1}{4}$ " DensDeck, loose laid

One or more layers of any of the following insulation:

<u>Insulation Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
Any approved polyisocyanurate listed in Table 2		
Minimum: 1.0" thick	N/A	N/A

Note: All insulation shall be preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimensions greater than 4 ft., and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: GenFlex TPO or TPO Plus attached to deck as follows:

Fastening #1: GenFast Polymer Batten Strips and GenFast #15 (WH) Fasteners spaced maximum 6 in. o.c. within minimum 4.5 in. wide laps. Laps are spaced maximum 69.5 in. o.c. and sealed with a min 1.0 in. wide inside edge heat weld and a min. 1.25 in. wide outside edge heat weld.

Maximum Design Pressure: -90.0 psf (See General Limitation #7)

Fastening #2: GenFast Polymer Batten Strips and GenFast #15 (WH) Fasteners spaced maximum 6 in. o.c. within minimum 6 in. wide laps. Laps are spaced maximum 114 in. o.c. and sealed with a min 1.0 in. wide inside edge heat weld and a min. 1.25 in. wide outside edge heat weld.

Maximum Design Pressure: -60.0 psf (See General Limitation #7)

Maximum Design Pressure:

See Membrane Fastening Options Above

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. steel
System Type D(7): Membrane attached over preliminary fastened insulation

All General and System Limitations apply.

Fire Barrier: (Optional) Minimum $\frac{5}{8}$ " gypsum board or $\frac{1}{4}$ " DensDeck, loose laid
 One or more layers of any of the following insulation:

<u>Insulation Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
Any approved insulation listed in Table 2		
Minimum: 0.25" thick	N/A	N/A

Note: All insulation shall be preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimensions greater than 4 ft., and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: Min. 0.070 thick GenFlex TPO Plus attached to deck as follows:
Fastening #1: GenFast Polymer Batten Strips and GenFast #15 (WH) Fastener spaced maximum 6 in. o.c. within min. 6 in. wide laps. Laps are spaced at maximum 69 in. o.c. and sealed with a minimum 1.0 in. wide inside edge heat weld and a minimum 1.5 in. wide outside edge heat weld.

Maximum Design Pressure: -75.0 psf (See General Limitation #7)

Fastening #2: ITW 2-3/8" Eyehook plates and GenFast #15 (WH) Fasteners spaced maximum 6 in. o.c. within minimum 6 in. wide lap. Laps are spaced at maximum 90 in. o.c. and sealed with minimum 1.5 in. wide heat weld on the outside edge of the lap. An intermediate row GenFast Polymer Batten Strips and GenFast #15 (WH) Fasteners spaced maximum 6 in. o.c. Intermediate row is centered between lap rows and covered with a 5 in. wide cover strip with minimum 1.5 in. wide heat welds on each side.

Maximum Design Pressure: -97.5 psf (See General Limitation #7)

Fastening #3: ITW 2-3/8" Eyehook plates and GenFast #15 (WH) Fasteners spaced maximum 6 in. o.c. within minimum 6 in. wide lap. Laps are spaced at maximum 69 in. o.c. and sealed with minimum 1.5 in. wide heat weld on the outside edge of the lap.

Maximum Design Pressure: -82.5 psf (See General Limitation #7)

Maximum Design Pressure: See Membrane Fastening Options Above

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. steel
System Type D(8): Membrane attached over preliminary fastened insulation

All General and System Limitations apply.

Fire Barrier: (Optional) Minimum $\frac{5}{8}$ " gypsum board or $\frac{1}{4}$ " DensDeck, loose laid
 One or more layers of any of the following insulation:

<u>Insulation Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
-------------------------	----------------------------------------	----------------------

Any approved insulation listed in Table 2

Minimum: 0.25" thick	N/A	N/A
----------------------	-----	-----

Note: All insulation shall be preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimensions greater than 4 ft., and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: GenFlex TPO or GenFlex TPO Plus attached to deck as follows:

Fastening : GenFast 3" Max Seam Plates and GenFast #16 Max Fasteners spaced maximum 6 in. o.c. within min. 6 in. wide laps. Laps are spaced at maximum 90 in. o.c. and sealed with a minimum 1.5 in. wide heat weld on outside edge.

Maximum Design Pressure: -67.5 psf (See General Limitation #7)

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. steel
System Type D(9): Membrane attached over preliminary fastened insulation

All General and System Limitations apply.

Deck: 18-22 ga., 1.5 in (38mm) deep, ASTM A653 or A1008 Grade 80 steel deck secured to 0.25 in (6mm) structural supports spaced a maximum 6 ft o.c. with Buildex Tek 4 or Tek 5 fasteners spaced max. 6 in o.c.

Fire Barrier: (Optional) Minimum $\frac{5}{8}$ " gypsum board or $\frac{1}{4}$ " DensDeck, loose laid

One or more layers of any of the following insulation:

<u>Insulation Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
Any approved insulation listed in Table 2		
Minimum: 0.25" thick	N/A	N/A

Note: All insulation shall be preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimensions greater than 4 ft., and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: Min. 0.070 in. thick GenFlex TPO Plus attached to deck as follows:

Fastening #1: GenFast 3" Max Seam Plates and GenFast #16 Max Fasteners spaced maximum 12 in. o.c. within minimum 6 in. wide lap. Laps are spaced maximum 69.75 in. o.c. and sealed with a minimum 1.5 in. wide heat weld on outside edge of lap.

Maximum Design Pressure: -52.5 psf (See General Limitation #7)

Fastening #2: GenFast (WH) 2-3/8" Seam Plate and GenFast #15 (WH) Fasteners or GenFast 3" Max Seam Plates and GenFast #16 Max Fasteners spaced maximum 6 in. o.c. within minimum 6 in. wide laps. Laps are spaced maximum 69.75 in. o.c. and sealed with minimum 1.5 in. heat weld on outside edge of lap.

Maximum Design Pressure: -75.0 psf (See General Limitation #7)

Fastening #3: GenFast 3" Max Plate and GenFast #16 Max Fasteners spaced maximum 6 in. o.c. within minimum 6 in. wide laps. Laps are spaced maximum 90 in. o.c. and sealed with minimum 1.5 in. heat weld on outside edge of lap.

Maximum Design Pressure: -82.5 psf (See General Limitation #7)

Maximum Design Pressure: See Membrane Fastening Options Above

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. steel
System Type D(10): Membrane attached over preliminary fastened insulation

All General and System Limitations apply.

Deck: 18-22 ga., 1.5 in (38mm) deep, ASTM A653 or A1008 Grade 80 steel deck secured to 0.25 in (6mm) structural supports spaced a maximum 6 ft o.c. with Buildex Tekes 4 or Tekes 5 fasteners spaced max. 6 in o.c.

Fire Barrier: (Optional) Minimum $\frac{5}{8}$ " gypsum board or $\frac{1}{4}$ " DensDeck, loose laid

One or more layers of any of the following insulation:

<u>Insulation Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
Any approved insulation listed in Table 2		
Minimum: 0.25" thick	N/A	N/A

Note: All insulation shall be preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimensions greater than 4 ft., and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: GenFlex TPO or GenFlex TPO Plus attached to deck as follows:
 GenFast 3" Max Seam Plates and GenFast #16 Max Fasteners spaced maximum 6 in. o.c. within minimum 6 in. wide lap. Laps are spaced maximum 90 in. o.c. and sealed with a minimum 1.5 in. wide heat weld on outside edge of lap.

Maximum Design Pressure: -67.5 psf (See General Limitation #7)

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. steel
System Type D(11): Membrane attached over preliminary fastened insulation

All General and System Limitations apply.

Deck: 18-22 ga., 1.5 in (38mm) deep, ASTM A653/A653M-01 Grade 33 steel deck secured to 0.25 in (6mm) structural supports spaced a maximum 6 ft o.c. with ITW Buildex ICH Traxx/5 fasteners spaced max. 6 in o.c. Side laps secured with ITW Buildex ICH Traxx/1 fasteners spaced max 24 in o.c.

Fire Barrier: (Optional) Minimum $\frac{5}{8}$ " gypsum board or $\frac{1}{4}$ " DensDeck, loose laid
 One or more layers of any of the following insulation:

<u>Insulation Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
Any approved polyisocyanurate listed in Table 2		
Minimum: 1.5" thick	N/A	N/A

Note: All insulation shall be preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimensions greater than 4 ft., and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: GenFlex TPO or GenFlex TPO Plus attached to deck as follows:
 GenFlex 2-3/8" Barbed Seam Plates and GenFast #16 Max Fasteners spaced maximum 6 in. o.c. within minimum 6 in. wide lap. Laps are spaced maximum 90 in. o.c. and sealed with a minimum 1.5 in. wide heat weld on outside edge of lap.

Maximum Design Pressure: -60.0 psf (See General Limitation #7)

Membrane Type: Single Ply, TPO
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. steel
System Type D(12): Membrane attached over preliminary fastened insulation

All General and System Limitations apply.

Deck: 18-22 ga., 1.5 in (38mm) deep, ASTM A653/A653M-01 Grade 33 steel deck secured to 0.25 in (6mm) structural supports spaced a maximum 6 ft o.c. with two ITW Buildex ICH Traxx/5 fasteners spaced max. 6 in o.c. Side laps secured with ITW Buildex ICH Traxx/1 fasteners spaced max 12 in o.c.

Fire Barrier: (Optional) Minimum $\frac{5}{8}$ " gypsum board or $\frac{1}{4}$ " DensDeck, loose laid
 One or more layers of any of the following insulation:

<u>Insulation Layer</u>	<u>Fastener Density ft²</u>	<u>Fastener Type</u>
Any approved polyisocyanurate listed in Table 2		
Minimum: 1.5" thick	N/A	N/A

Note: All insulation shall be preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimensions greater than 4 ft., and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: GenFlex TPO or GenFlex TPO Plus attached to deck as follows:
 GenFlex 2-3/8" Barbed Seam Plates and GenFast #16 Max Fasteners spaced maximum 6 in. o.c. within minimum 6 in. wide lap. Laps are spaced maximum 90 in. o.c. and sealed with a minimum 1.5 in. wide heat weld on outside edge of lap.
 $\frac{3}{4}$ " GenFast Polymer Batten Strip installed with GenFast #15 Fasteners spaced minimum 6 in o.c. between each lap. Batten Strip covered with TPO coverstrip minimum 5 in. wide and minimum 1½" wide heat welds on both edges.

Maximum Design Pressure: **-105.0 psf** (See General Limitation #7)

STEEL DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117 and/or RAS 137, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 11-0330.14
Expiration Date: 07/17/13
Approval Date: 06/14/12
Page 24 of 24